## Gwydir Shire Council

## Bingara Sewerage Treatment Plant - EPA License 586 - Yearly Summary

## Point 1: Yearly Summary November 2018 to October 2019

Note: discharge only occurred during July, August, September and October 2019

		90 percentile concentration	Frequency required	Number of data points				
Pollutant	Units	limit	by the License	for the year	Minimum value	Maximum value	Mean	Exceedences
Biochemical oxygen demand (BOD)	mg/L	20	Special Frequency	4	16	28	21	Yes
Total suspended solids (TSS)	mg/L	30	Special Frequency	4	4	23	14	No
Oil and Grea	mg/L	10	Special Frequency	4	5	7	5.5	No
pН	pН		Special Frequency	4	7.8	7.9	7.8	
Conductivity Nitrate+nitrit e (oxidised	ms/cm		Special Frequency	4	0.63	0.74	0.69	
nitrogen)	mg/L		Special Frequency	4	2.7	9.6	5.1	
Nitrogen (am	mg/L		Special Frequency	4	5.9	11.7	8.4	
Phosporous	mg/L		Special Frequency	4	5.4	7.2	6.2	
Total Kjeldal	mg/L		Special Frequency	4	7.2	12.7	10.5	
Faecal Colifo	CFU/100ml		Special Frequency	4	2	980	305	

Point 3: Yearly Summary November 2018 to October 2019 Note: Samples collected at point 3 on the following months - Nov 18, Dec 18, Jan 19, Feb 19, March 19, April 19, May 19 and June 19

		90 percentile	Monitoring Frequency required	Number of data points				
Pollutant	Units	limit	by the License	for the year	Minimum value	Maximum value	Mean	Exceedences
Biochemical oxygen demand					0	05	10	NA
(BOD)	mg/L	20	Special Frequency	8	6	85	19	NA - no discharge
Total suspended solids (TSS)	mg/L	30	Special Frequency	8	5	52	26	NA - no discharge
Oil and Grea	mg/L	10	Special Frequency	8	5	5	5	NA - no discharge
pН	pН		Special Frequency	8	7	9.5	8.5	
Conductivity	ms/cm		Special Frequency	8	0.56	0.87	0.63	
Nitrate+nitrit e (oxidised								
nitrogen)	mg/L		Special Frequency	8	0.7	6.2	2.1	
Nitrogen (am	mg/L		Special Frequency	8	0.1	11.3	4.4	
Phosporous	mg/L		Special Frequency	8	1.8	6.1	4.1	
Total Kjeldal	mg/L		Special Frequency	8	2.5	15.1	7.1	
Faecal Colifo	CFU/100ml		Special Frequency	8	2	64000	10543	