Gwydir Shire Council

Warialda Sewerage Treatment Plant - EPA License 584 - monitoring point summary

EPA identification No:	Type of monitoring	Type of Point	Location Description
1	Volume Monitoring (KL/day)	Inlet to works	Inlet to works - ultrasonic flow unit
2	Effluent Quality	Discharge to waters	monthly grab sample
2	Volume Monitoring	Discharge to waters	outlet to Reedy creek - ultrasonic flow unit
3	Total volume monitoring	Discharge to utilisation area	Water meter located at Warialda golf course
4	Volume Monitoring	Discharge to waters	overflow outlet at Warialda STP

	Warialda STP inflow (1)			EPA year		w	Warialda STP outflow (2)			Warialda golf recycled (3)				
Year	Low	mean	High	TOTAL	Water	rainfall	Low	mean	High	TOTAL	Low	mean	High	TOTAL
2015/16	1	3 11	316	177170	281070	779	0	89	714	32079	0	231	1397	21000
2016/17	2	2 10:	326	171810	292801	658	0	20	936	49980	0	750	4719	25000
2017/18	2	5 9	285	155000	341796	491	0	38	63	28060	0	3800	6360	31278
2018/19	5	9	250	130238	361773	267	0	26	42	18233	0	3033	6860	39635
2019/20														